



# LNE

Le progrès, une passion à partager

LABORATOIRE DE TRAPPES  
29 avenue Roger Hennequin - 78197 Trappes Cedex  
Tél : 01 30 69 10 00 - Fax : 01 30 69 12 34

## CLASSIFICATION REPORT

(free translation of French test report)  
established according to the article 5 of the Department State Order dated on  
21 November 2002.

VALIDITY 5 YEARS FROM 25 June 2007

**N° G110166 - CEMATE/7**

and appendix of 4 pages

**Material submitted by** : POLYREY SAS  
Usine de Couze  
24150 LALINDE

**Commercial trademark** : POLYREY HPL ININFAMMABLE

**Brief description** :

**Global composition** : High pressure decorative stratified panel carried out with packed Kraft paper sheets impregnated of fire proof phenolic resin, covered of a paper impregnated plain decoration or printed decoration + overlay. Product fireproofed in mass. Punch n° 86.

**End-use** : Furnishing, internal walls, ceilings, offices, etc...

**Mass** : (1420) kg/m<sup>3</sup>

**Thickness** : (0,8 to 24 ± 5 %) mm

**Colour** : Various

**Test report** : N° G110166 - CEMATE/2 dated on 25 June 2007

**Type of tests** : Heat radiation test.

**Classification** : **M1**

**Durability of classification (appendix 22)** : Unlimited a priori

In view of criteria resulting from the tests described in the appended Test Report N° G110166 - CEMATE/2.

The indicated classification prejudices in no way the conformity of the materials commercialized to the samples submitted to the tests and can in no way be considered as a certificate of qualification.  
This is not a product certification according to the L115-27 article of the consumption code and to the law dated on 3<sup>rd</sup> June 1994.

**Note** : Only full reproduction and by photocopy of the present classification report or the whole classification report and the appended test report are authorized

Trappes, 25 June 2007

The Head of the Fire  
Behaviour Division

Alain SAINRAT



Test officer  
Marc LE QUERE  
The Responsible for Test

  
Guillaume LE GOFF

cofrac



ESSAIS

Accréditation  
N° 1-0606  
Portée disponible  
sur [www.cofrac.fr](http://www.cofrac.fr)

### Laboratoire national de métrologie et d'essais

Établissement public à caractère industriel et commercial • Siège social : 1, rue Gaston Boissier 75724 Paris Cedex 15 • Tél. : 01 40 43 37 00  
Fax : 01 40 43 37 37 • E-mail : [info@lne.fr](mailto:info@lne.fr) • Internet : [www.lne.fr](http://www.lne.fr) • Siret : 313 320 244 00012 • NAF : 743 B • TVA : FR 92 313 320 244  
Barclays Paris Centrale IBAN : FR76 3058 8600 0149 7267 4010 170-BIC : BARCFRPP